

National Building Specification**FireSafe 60****Product Reference:**

FireSafe 60

Automatic Fire Barrier

Approved Standards:

BS 476-22:1987

BS 476-6:1989+A1:2009

BS 476-7:1997

Description:

The FireSafe 60 is an electrically operated Automatic Fire Barrier, to be used to form a barrier against fire.

Product Performance:

Complete product tested to BS 476-22:1987, Clause 8 and achieved a rating of above 60 minutes.

Designed to operate for over 2 000 cycles at normal ambient temperatures in the range of 0°C to 60°C.

The FireSafe 60 can be provided to protect openings widths of up to 6 m and heights up to 6.6 m.

General Description:

The Automatic Fire Barrier head box is manufactured from 1.2 mm zintec steel with removable cover plates allowing access to the fabric curtain roller. Standard head box sizes are 160 mm x 160 mm with larger head boxes where the fabric curtain drop is in excess of 3 m. A suitably weighted bottom bar is provided to prevent deflection and ensure correct operation under gravity.

The roller is constructed from a steel tube, which incorporates a 24Vdc motor. The fabric curtain is manufactured from reinforced glass fibre fabric. The curtain fabric is made from filament glass fibre, treated with proprietary finish to enhance temperature resistance. Both sides of the fabric are coated with a flame-retardant silver-grey aluminium filled polymer. The weight is approx. 450 g/m² in its finished form. Fabric thickness is nominally 0.4 mm and the weave is an 4-end satin.

Side guides retain the fabric curtain edges and are installed either side to provide a seal between the fabric curtain and the surrounding construction.

FireSafe 60 has fixing options to suit brick and concrete surrounds and can be integrated into either a suspended or a solid ceiling. It remains hidden until required. Upon receiving a signal from the fire detection system or on loss of power the Automatic Fire Barrier unwinds to its fire operational position by gravity.



Global Fire Control Solutions

Smoke & Fire Curtains Ltd

9 Brook Street, Syston, Leicester, LE7 1GD

t: +44 (0)330 0539660

e: enquiries@firecurtainsltd.com

w: www.firecurtainsltd.com

Control System:

The control panel [model FC- 01 GFS] meets the following EU Directives: Low Voltage Directive 2006/95/EC and Electromagnetic Compatibility Directive 2004/108/EC.

Under normal operating conditions the Automatic Fire Barrier would be held in the retracted position via the motor operating at low voltage. Upon activation of the fire alarm the control panel will remove the supply voltage and the Automatic Fire Barrier will descend under gravity in a controlled manner. A dynamic braking system housed in the motor control circuit controls the speed of descent.

To retract the Automatic Fire Barrier the control panel supplies 24Vdc to the motor which drives the Automatic Fire Barrier to the upper position. As the bottom bar interfaces with the head box the limit setting holds the bottom bar in the retracted position.

Should the mains power fail to the control panel the supply is automatically switched to the integral standby battery. The Automatic Fire Barrier remains in the retracted position for 24 hrs. The Automatic Fire Barrier will remain fully operational until the battery low voltage cut off facility reads a voltage of 21V, the Automatic Fire Barrier will then safely descend under gravity to its fire operational position.



Global Fire Control Solutions

Smoke & Fire Curtains Ltd

9 Brook Street, Syston, Leicester, LE7 1GD

t: +44 (0)330 0539660

e: enquiries@firecurtainsltd.com

w: www.firecurtainsltd.com

Optional Extra's

Split Drop:

An optional braking system is available to allow a stage descent during deployment. Partial descent to a predetermined level to permit preliminary escape and initial smoke containment at high level, after the delay the Automatic Fire Barrier descends to its fire operational position.

Delay on Alarm:

The control panel can be programmed to allow a timer delay on the alarm for a number minutes before the Automatic Fire Barrier descends to its fire operational position.

Beam Sensor

A beam sensor can be used as either a block sensor or an override; when the fire alarm activates and someone under the Automatic Fire Barrier the beam sensor can be wired to either stop or to retract the Automatic Fire Barrier. Please note that when used in isolation the beam sensor does not trigger a sound.

Emergency Over Ride Switches:

Hold on retract facility for escape and emergency service access.

Visual Alert System:

Flashing beacon and sounder can be connected via the control panel and provide a warning when the Automatic Fire Barriers about to descend. When the fire alarm is triggered the Automatic Fire Barrier deploys the beacon will flash with a sounder alert until the signal from the alarm is lost. Please note that when used in isolation the audio-visual unit does not stop the Automatic Fire Barrier descending and/or retract the Automatic Fire Barrier.

Smoke & Fire Curtains Ltd. has a policy of continuous product improvement. As such we reserve the right to change design and specifications without prior notice. Please check our website for the latest information.